

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7167-1645:141

Page 1 of 1

**CATEGORY:** Control Unit (Household)

**LISTEE:** ADEMCO, DBA Honeywell International Inc.,  
2 Corporate Center Drive, Ste 100, Melville, New York 11747  
Contact: David Kalmus (516) 921-6704 Ext 1910 Fax (516) 364-6953

**DESIGN:** Models LYNX, "ReadyGuard", LYNXR24, LYNXR24-SP, LYNXR-EN, CFLYNXR-EN, LYNX-R, LYNXR-SP, LYNXR-I, LYNXR-IFR, ReadyGuard-R, ReadyGuard-RI, ReadGuard-REN, LYNXR-ENSIA, \*APX32, \*APX32SIA, \*LYNXR-ISIA, ReadyGuard-RISIA and \*ReadyGuard-RENSIA combination fire and burglary alarm control units. Units are self-contained, microprocessor-based programmable systems with integral digital alarm communicator transmitter housed within a plastic enclosure. \*All units may be used with Dialer Capture Intelligence Device Model DCID. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 120 VAC, 9 VAC, Class 2 Transformer, 9 VDC battery

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and \*WHI Certification Mark.

**APPROVAL:** Listed as a combination household fire and burglary alarm control units for use with the separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

**NOTE:** 1. Formerly 7167-0078:192  
\*2. Burglary and other non-fire functions were not examined.

\*Rev. 05-14-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*

